PORTABLE APPLIANCE TEST REPORT

CERTIFICATE REF: PAT/9444AB

CONTRACTOR DETAILS		SITE DETAILS	CLIENT DETAILS
M&S Electrical Services Ltd	M&S Electrical Services Limited 12 Bullfinch Close Riverhead England TN13 2BB	Seal Church	Seal Church Seal Church
Website:		Email: simon-bull@hotmail.co.uk	Email: simon-bull@hotmail.co.uk
Telephone: 01732 247660		Telephone:	Telephone:

#	ID	MAKE	MODEL	LOCATION	SERIAL NO	VISUAL INSPECTION	VOLTAGE (V)	EARTH CONTINUITY (Ω)	POLARITY	PASS / FAIL
1	Heater			Church		PASS	240	19.99	PASS	PASS
2	Heater			Church		PASS	240	19.99	PASS	PASS
3	Fridge			Church hall		PASS	240	0.11	PASS	PASS
4	Coffee machine			Church hall		PASS	240	19.99	PASS	PASS
5	Kettle	Brita		Church hall		PASS	240	0.04	PASS	PASS
6	Urn	Swan		Church hall		PASS	240	19.99	PASS	PASS
7	Microwave	Russell Hobbs		Church hall		PASS	240	0.07	PASS	PASS
8	Urn	Swan		Church hall		PASS	240	19.99	PASS	PASS
9	Extension lead			Church hall		PASS	240	0.14	PASS	PASS
10	Piano			Church hall		PASS	240	19.99	PASS	PASS
11	Heater			Church hall		PASS	240	19.99	PASS	PASS
12	Heater			Church hall		PASS	240	0.07	PASS	PASS
13	Toaster			Church hall		PASS	240	0.25	PASS	PASS

REASON FOR FAILURES: None	Engineer Name: Michael Evans	Date: 7/07/2025
	Engineer Signature:	Next Inspection: 07/07/2026